

Florida Test



Total duration: 12 months



**EXPOSURE PERIOD:** 

FROM: 21/11/2019

TO: 11/01/2021

LAB. ID NUMBER: 46265
POWDER COATING: DS 708
HEAT TRANSFER FILM: 5014/06
colour variation (ΔΕ): **0,52**residual gloss: **75**%

## **Technical Remarks**

Good residual gloss and normal colour variation ( $\Delta E$ )

## **Technical Opinion:**

## **Suitable for OUTDOOR USE**

Test was carried on samples prepared according to technical specifications supplied by raw materials manufacturers.

## REQUIREMENTS

The residual gloss must be at least 50% of the original gloss. The final evaluation will be based on visual inspection with the naked eye

