

Florida Test



Total duration: 12 months



**EXPOSURE PERIOD:** 

FROM: 01/05/2021

TO: 01/05/2022

LAB. ID NUMBER: 50135 POWDER COATING: DS 769 HEAT TRANSFER FILM: 2507/07 colour variation (ΔΕ): **1,49** residual gloss: **73**%

## **Technical Remarks**

Good residual gloss and normal colour variation ( $\Delta E$ )

## **Technical Opinion:**

## **Suitable for OUTDOOR USE**

Test was carried on samples prepared according to technical specifications supplied by raw materials manufacturers.

## REQUIREMENTS

The residual gloss must be at least 50% of the original gloss. The final evaluation will be based on visual inspection with the naked eye

